

**THE WAVE TRANSIT SYSTEM
MOBILE, ALABAMA**

**BUS SHELTERS INSTALLATION- PHASE 4,
PRE- BID MEETING**

ADDENDUM NUMBER 1

September 7, 2010

The following items are to be added to the Construction Documents and will be a part of the Construction Contract between the Owner and General Contractor.

PROJECT NAME: Bus Shelter Installation - Phase 4
PROJECT NUMBER: MT-052-09
BY: Gary L. Jackson, Project Manager
Leon Bell, Jr., Grants Administrator

<i>ATTENDEES</i>	<i>DISTRIBUTION</i>
<ul style="list-style-type: none">• Gary L. Jackson, AE, City of Mobile• Gerald Alfred, Wave Transit System• Leon Bell, Jr., Wave Transit System• Jim Lignos, Ladas Construction• Lee Sterling, Sterling Construction	<ul style="list-style-type: none">• All Meeting Attendees• Bill DeMouy, REAM• John Crawford, AE, Director• Tyrone Parker, Wave Transit System, General Manager• Fred Fambrough, AE Dept.• File
<i>ITEMS DISCUSSED:</i>	<i>INFORMATION; ACTION TAKEN, OR ACTION REQUIRED</i>
<ul style="list-style-type: none">• Building Risk Insurance• Concrete: Pad Sizes/ Testing	<ul style="list-style-type: none">• Contractor shall be responsible for providing Builders Risk Insurance with proposal.• Concrete Pad Size shall be (6'-0" x 11'-0"); 6" Deep. See Section 03300. Elevations shall be equal to adjacent Walkway. Field verifies all existing conditions.• Concrete Testing Cost is part of the Contractor's Scope of Work, See Section 03300, Concrete, 1.10 Field Quality Control.• Concrete Shall Have A (28) Day Compression Test On Each Individual Pad

- **Installation of Bus Shelters**

- Five Shelters to be install; shelters are in storage at Wave Transit Facility, Contractor can inspect shelter containments at 1224 West I-65 Service Road South. Contact Person for shelters inspection is Charles Semrall, Director of Maintenance.
- The bus shelter sites will be cleared of any existing Wave Bus Shelters. Contractor will be responsible for preparing area for concrete footing.
- No forklift will be available. Contractor will have to provide forklift or a machine to load the shelters onto a trailer or truck?

- **Bid Form Section 00410 Correction**

- City of Mobile Business License is not required for bidding purpose. The selected Contractor must have/ acquire a City's Business License before entering into an AIA contract agreement with the Wave Transit. The City of Mobile is the governing municipality of the Wave Transit System.
- Bid must be received at the Wave Transit GM&O location by 2:15 p.m. Wednesday, **October 15, 2010**. The Bids will be formally opened at 2:30 p.m. in the Wave Transit Conference Room, See Section 00100 Invitation to Bid

- **Allowance**

- There is a **\$2,000.00** allowance for any unforeseen items that occur during the installation of the Bus Shelters. All unused allowance will be credited back to the Wave Transit in the form of a Change Order.

- **Bid Clarification Contact Number/ E-mail**

- All questions shall be directed to Gary Jackson, AE, 208-7596 Work; 208-7894 Faxed; 472-5064 City Cell; E-mail gary.jackson@cityofmobile.org

These notes represent my understanding of the discussion, summarized and paraphrased. Please address any corrections, questions or comments regarding these notes to me.